

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
East Sylvan Site - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
372-DF6082-NA-005-A	Staff Room	12/14/2022	12/16/2022	A2L0572-01	Lead	0.978	0.2	15	ppb
372-DF6083-NA-005-A	Classroom 19	12/14/2022	12/16/2022	A2L0572-02	Lead	0.304	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb

Page 1 of 1