

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Edwards - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
246-DF-3816-A-004-A	Therapy Room 10	6/29/2022	6/30/2022	A2G0037-01	Lead	2.61	0.2	15	ppb
246-DF-3822-A-004-A	Classroom 5	6/29/2022	6/30/2022	A2G0037-02	Lead	0.595	0.2	15	ppb
246-DF-3830-NA-004-A	Therapy Room	6/29/2022	6/30/2022	A2G0037-03	Lead	2.14	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb

Page 1 of 1