Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Edwards Site - Test 6

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
246-DF3828-NA-006-A	Classroom 7	9/21/2022	9/22/2022	A2I0657-01RE1	Lead	0.246	0.200	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb