

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
George Middle School - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
156-DF-2849-A-005-A	Hallway	08/12/2021	08/23/2021	A1H0403-01	Lead	ND	0.2	15	ppb
156-DF-2843-N/A-005-A	Office	08/12/2021	08/23/2021	A1H0403-02	Lead	0.694	0.2	15	ppb
156-DF-2809-A-005-A	Hallway	08/12/2021	08/23/2021	A1H0403-03	Lead	ND	0.2	15	ppb
156-DF-2841-A-005-A	Hallway	08/12/2021	08/23/2021	A1H0403-04	Lead	ND	0.2	15	ppb
156-DF-5791-N/A-005-A	Classroom	08/12/2021	08/23/2021	A1H0403-05	Lead	2.05	0.2	15	ppb
156-DF-2807-A-005-A	Hallway	08/12/2021	08/23/2021	A1H0403-06	Lead	ND	0.2	15	ppb
156-DF-2786-A-005-A	Hallway	08/12/2021	08/23/2021	A1H0403-07	Lead	ND	0.2	15	ppb
156-DF-5800-N/A-005-A	Kitchen	08/12/2021	08/23/2021	A1H0403-08	Lead	0.342	0.2	15	ppb
156-DF-2804-A-005-A	Cafeteria	08/12/2021	08/23/2021	A1H0403-09	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb

Page 1 of 1