

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Grant Site - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
217-DF-5600-A-004-A	Hallway (Classroom 077)	2/14/2023	2/16/2023	A3B0497-01RE1	Lead	ND	0.2	15	ppb
217-DF-5601-A-004-A	Hallway (Dance Studio 041)	2/14/2023	2/16/2023	A3B0497-02RE1	Lead	ND	0.2	15	ppb
217-DF-5602-A-004-A	Hallway (Dance Studio 041)	2/14/2023	2/16/2023	A3B0497-03RE1	Lead	ND	0.2	15	ppb
217-DF-5603-A-004-A	Hallway (Health Classroom 027)	2/14/2023	2/16/2023	A3B0497-04RE1	Lead	ND	0.2	15	ppb
217-DF-5604-A-004-A	Hallway (Gym North)	2/14/2023	2/16/2023	A3B0497-05RE1	Lead	ND	0.2	15	ppb
217-DF-5605-A-004-A	Hallway (Gym South)	2/14/2023	2/16/2023	A3B0497-06RE1	Lead	ND	0.2	15	ppb
217-DF-5608-A-004-A	Hallway (Classroom 177)	2/14/2023	2/16/2023	A3B0497-07RE1	Lead	ND	0.2	15	ppb
217-DF-5617-A-004-A	Hallway (Classroom 125)	2/14/2023	2/16/2023	A3B0497-08RE1	Lead	ND	0.2	15	ppb
217-DF-5622-A-004-A	Hallway (Gymnasiums)	2/14/2023	2/16/2023	A3B0497-09RE1	Lead	ND	0.2	15	ppb
217-DF-5623-A-004-A	Hallway (A100)	2/14/2023	2/16/2023	A3B0497-13RE1	Lead	ND	0.2	15	ppb
217-DF-5624-A-004-A	Hallway (Classroom 277)	2/14/2023	2/16/2023	A3B0497-10RE1	Lead	ND	0.2	15	ppb
217-DF-5625-A-004-A	Hallway (Classroom 227)	2/14/2023	2/16/2023	A3B0497-11RE1	Lead	ND	0.2	15	ppb
217-DF-5627-A-004-A	Hallway (Daycare A009)	2/14/2023	2/16/2023	A3B0497-12RE1	Lead	ND	0.2	15	ppb
217-DF-6238-A-004-A	Hallway (Small Instruction 196)	2/14/2023	2/16/2023	A3B0497-14RE1	Lead	0.740	0.2	15	ppb
217-DF-6243-A-004-A	Hallway (Text Storage 132)	2/14/2023	2/16/2023	A3B0497-15RE1	Lead	0.603	0.2	15	ppb
217-DF-6249-A-004-A	Hallway (A200)	2/14/2023	2/16/2023	A3B0497-16RE1	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories

*OHA Action Level = 15ppb

Reviewed by: PBS Engineering and Environmental

Page 1 of 1