

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Green Thumb Site - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
305-DF-1307-A-004-A	Outside (Portable 3)	8/4/2022	8/12/2022	A2H0201-01RE1	Lead	0.703	0.2	15	ppb
305-DF-1310-A-004-A	Hallway (Portable 1)	8/4/2022	8/12/2022	A2H0201-02RE1	Lead	ND	0.2	15	ppb
305-DF-6121-NA-004-A	Portable 2	8/4/2022	8/12/2022	A2H0201-03RE1	Lead	2.19	0.2	15	ppb
305-DF-6127-NA-004-A	Office	8/4/2022	8/12/2022	A2H0201-04RE1	Lead	ND	0.2	15	ppb
305-DF-6128-NA-004-A	Kitchen	8/4/2022	8/12/2022	A2H0201-05RE1	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories

*OHA Action Level = 15ppb

Reviewed by: PBS Engineering and Environmental

Page 1 of 1