

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Harrison Park School - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
236-DF-1856-A-004-A	Cafeteria	2/9/2021	2/10/2021	A1B0310-11	Lead	ND	0.2	15	ppb
236-DF-1399-A-004-A	Classroom 169B	2/9/2021	2/10/2021	A1B0310-12	Lead	ND	0.2	15	ppb
236-DF-1792-A-004-A	Hallway (169)	2/9/2021	2/10/2021	A1B0310-13	Lead	ND	0.2	15	ppb
236-DF-5839-N/A-004-A	Staff Room 136	2/9/2021	2/10/2021	A1B0310-14	Lead	0.529	0.2	15	ppb
236-DF-5840-A-004-A	Hallway (198)	2/9/2021	2/10/2021	A1B0310-15	Lead	ND	0.2	15	ppb
236-DF-5841-A-004-A	Hallway (115)	2/9/2021	2/10/2021	A1B0310-16	Lead	ND	0.2	15	ppb
236-DF-5842-A-004-A	Hallway (206B)	2/9/2021	2/10/2021	A1B0310-17	Lead	ND	0.2	15	ppb
236-DF-1850-A-004-A	Hallway (Office)	2/9/2021	2/10/2021	A1B0310-18	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb