

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Hosford Middle School - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
257-DF-6009-N/A-004-A	Staff Room (106)	8/27/2021	8/31/2021	A1H0917-13	Lead	1.08	0.2	15	ppb
257-DF-6012-N/A-004-A	Health Room (Room 2)	8/27/2021	8/31/2021	A1H0917-14	Lead	0.764	0.2	15	ppb
257-DF-6011-N/A-004-A	ISC Classroom (5)	8/27/2021	8/31/2021	A1H0917-15	Lead	1.3	0.2	15	ppb
257-DF-6010-N/A-004-A	ISC Classroom (6)	8/27/2021	8/31/2021	A1H0917-16	Lead	0.827	0.2	15	ppb
257-DF-3706-N/A-004-A	Art Room	8/27/2021	8/31/2021	A1H0917-17	Lead	0.528	0.2	15	ppb
257-DF-3708-N/A-004-A	Kitchen	8/27/2021	8/31/2021	A1H0917-18	Lead	3.24	0.2	15	ppb
257-DF-6007-N/A-004-A	Staff Room (121)	8/27/2021	8/31/2021	A1H0917-19	Lead	1.2	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb