

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Humboldt Site - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
164-DF-2227-A-004-A	Portable Classroom 2	8/4/2022	8/8/2022	A2H0178-01	1.35	Lead	1.35	15	ppb
164-DF-2230-NA-004-A	Classroom 17	8/4/2022	8/8/2022	A2H0178-03	1.11	Lead	1.11	15	ppb
164-DF-2248-A-004-A	Hallway (Classroom 12)	8/4/2022	8/8/2022	A2H0178-02	0.366	Lead	0.366	15	ppb
164-DF-6118-NA-004-A	Staff Room	8/4/2022	8/8/2022	A2H0178-04	2.18	Lead	2.18	15	ppb
164-DF-6120-NA-004-A	Portable Classroom 1	8/4/2022	8/8/2022	A2H0178-05	0.346	Lead	0.346	15	ppb

Analyzed by: Apex Laboratories

*OHA Action Level = 15ppb

Reviewed by: PBS Engineering and Environmental

Page 1 of 1