

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
James John - Test 6**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
166-DF-2763-A-006-A	Hallway (Office)	8/29/2022	9/1/2022	A2H0906-02	Lead	ND	0.2	15	ppb
166-DF-2772-A-006-A	Hallway (Classroom 21)	8/29/2022	9/1/2022	A2H0906-01	Lead	ND	0.2	15	ppb
166-DF-2773-A-006-A	Cafeteria	8/29/2022	9/1/2022	A2H0906-03	Lead	ND	0.2	15	ppb
166-DF-5792-N/A-006-A	Staff Room	8/29/2022	9/1/2022	A2H0906-04	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories

*OHA Action Level = 15ppb

Reviewed by: PBS Engineering and Environmental

Page 1 of 1