

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Jefferson High School - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
118-DF-3657-A-005-A	Outside Auditorium	8/27/2021	8/30/2021	A1H0917-01	Lead	0.258	0.2	15	ppb
118-DF-3660-A-005-A	Backstage	8/27/2021	8/30/2021	A1H0917-02	Lead	ND	0.2	15	ppb
118-DF-3610-N/A-005-A	Indian Education Room	8/27/2021	8/30/2021	A1H0917-03	Lead	0.627	0.2	15	ppb
118-DF-5809-N/A-005-A	Kitchen	8/27/2021	8/30/2021	A1H0917-04	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb