

Portland Public Schools
Lead Water Sampling Results
Drinking Fixture Replacement Program Sample Data
Martin Luther King Elementary School - Test 6

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
262-DF-1674-A-006-A	Hallway (122)	9/10/2020	9/15/2020	A0I0302-01	Lead	ND	0.2	15	ppb
262-DF-1667-A-006-A	Hallway (130)	9/10/2020	9/15/2020	A0I0302-02	Lead	1.35	0.2	15	ppb
262-DF-1699-A-006-A	Classroom 141	9/10/2020	9/15/2020	A0I0302-03	Lead	5.97	0.2	15	ppb
262-DF-1696-A-006-A	Cafeteria	9/10/2020	9/15/2020	A0I0302-04	Lead	ND	0.2	15	ppb
262-DF-1684-N/A-006-A	Kitchen	9/10/2020	9/15/2020	A0I0302-05	Lead	4.31	0.2	15	ppb
262-DF-1676-A-006-A	Hallway (211)	9/10/2020	9/15/2020	A0I0302-06	Lead	ND	0.2	15	ppb
262-DF-5913-A-006-A	Hallway (204)	9/10/2020	9/15/2020	A0I0302-07	Lead	ND	0.2	15	ppb
262-DF-1677-A-006-A	Hallway (239)	9/10/2020	9/15/2020	A0I0302-08	Lead	ND	0.2	15	ppb
262-DF-5777-N/A-006-A	Classroom 153	9/10/2020	9/15/2020	A0I0302-09	Lead	0.792	0.2	15	ppb
262-DF-1668-A-006-A	Hallway (151)	9/10/2020	9/15/2020	A0I0302-10	Lead	ND	0.2	15	ppb
262-DF-5785-N/A-006-A	Classroom 140	9/10/2020	9/15/2020	A0I0302-11	Lead	10.3	0.2	15	ppb
262-DF-5784-N/A-006-A	Staff Room	9/10/2020	9/15/2020	A0I0302-12	Lead	4.00	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb