

Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Laurelhurst Elementary School - Test 4

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
265-DF-5831-A-004-A	Hallway (213)	05/26/2021	06/08/2021	A1E1233-12	Lead	ND	0.2	15	ppb
265-DF-3747-A-004-A	Hallway (Office)	05/26/2021	06/08/2021	A1E1233-13	Lead	ND	0.2	15	ppb
265-DF-5827-A-004-A	Health Room	05/26/2021	06/08/2021	A1E1233-14	Lead	0.723	0.2	15	ppb
265-DF-5829-NA-004-A	Kitchen	05/26/2021	06/08/2021	A1E1233-15	Lead	16.8	0.2	15	ppb
265-DF-3738-A-004-A	Hallway (Classroom 5)	05/26/2021	06/08/2021	A1E1233-16	Lead	ND	0.2	15	ppb
265-DF-3733-A-004-A	Cafeteria	05/26/2021	06/08/2021	A1E1233-17	Lead	ND	0.2	15	ppb
265-DF-3736-A-004-A	North Gym	05/26/2021	06/08/2021	A1E1233-18	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb