

Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Laurelhurst Elementary School - Test 5

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
DF-5829-A-005-N/A	Kitchen	6/24/2021	6/25/2021	A1F0948-01	Lead	2.11	0.2	15	ppb
CH-3753-A-005-N/A	Kitchen	6/24/2021	6/25/2021	A1F0948-02	Lead	0.604	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb