

Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Jason Lee Elementary School - Test 5

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
264-DF-6087-A-005-A	N/A	1/22/2021	1/25/2021	A1A0791-01	Lead	0.358	0.2	15	ppb
264-DF-3762-A-005-A	Hallway by Classroom	1/22/2021	1/25/2021	A1A0791-02	Lead	ND	0.2	15	ppb
264-DF-3773-A-005-A	Cafetorium	1/22/2021	1/25/2021	A1A0791-03	Lead	ND	0.2	15	ppb
264-DF-3767-A-005-A	Hallway by Custodian	1/22/2021	1/25/2021	A1A0791-04	Lead	ND	0.2	15	ppb
264-DF-3784-A-005-A	Hallway by Boy's Locker	1/22/2021	1/25/2021	A1A0791-05	Lead	ND	0.2	15	ppb
264-DF-3805-A-005-A	Hallway by Classroom	1/22/2021	1/25/2021	A1A0791-06	Lead	0.326	0.2	15	ppb
264-DF-3808-NA-005-A	Classroom	1/22/2021	1/25/2021	A1A0791-07	Lead	0.769	0.2	15	ppb
264-DF-3761-NA-005-A	Classroom	1/22/2021	1/25/2021	A1A0791-08	Lead	1.35	0.2	15	ppb
264-DF-5701-NA-005-A	Staffroom	1/22/2021	1/25/2021	A1A0791-09	Lead	1.02	0.2	15	ppb
264-DF-3778-NA-005-A	Faculty	1/22/2021	1/25/2021	A1A0791-10	Lead	0.834	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb