

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Llewellyn Elementary - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
269-DF-5996-N/A-006-A	Staff Room (204)	8/27/2021	8/31/2021	A1H0917-27	Lead	0.553	0.2	15	ppb
269-DF-1295-N/A-006-A	Portable (Music)	8/27/2021	8/31/2021	A1H0917-28	Lead	0.646	0.2	15	ppb
269-DF-1272-N/A-006-A	Behavior Room (109)	8/27/2021	8/31/2021	A1H0917-29	Lead	0.596	0.2	15	ppb
269-DF-5994-N/A-006-A	Kitchen	8/27/2021	8/31/2021	A1H0917-30	Lead	2.92	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb