Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Markham Site - Test 5

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
170-DF6029-NA-005-A	Afterschool Program	9/2/2022	9/7/2022	A2I0058-01	Lead	1.26	0.200	15	ppb
170-DF6032-NA-005-A	Special Education Room	9/2/2022	9/7/2022	A2I0058-02	Lead	1.66	0.200	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb