

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Marshall Site - Test 7**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
220-DF6105-N/A-008-A	Daycare	12/15/2022	12/19/2022	A2L0694-01	Lead	0.598	0.2	15	ppb
220-DF6108-N/A-008-A	SES Classroom	12/15/2022	12/21/2022	A2L0694-02	Lead	0.764	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb