

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
MLC - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
154-DF-1978-A-003-A	Hallway (Boiler Room)	4/15/2022	4/19/2022	A2D0614-01	Lead	ND	0.2	15	ppb
154-DF-1979-A-003-A	Hallway (Classroom 204)	4/15/2022	4/19/2022	A2D0614-02	Lead	ND	0.2	15	ppb
154-DF-1980-A-003-A	Hallway (Classroom 300)	4/15/2022	4/19/2022	A2D0614-03	Lead	ND	0.2	15	ppb
154-DF-6075-N/A-003-A	Kitchen	4/15/2022	4/19/2022	A2D0614-07	Lead	30.5	0.2	15	ppb
154-DF-6076-N/A-003-A	Staff Room	4/15/2022	4/19/2022	A2D0614-08	Lead	0.290	0.2	15	ppb
154-DF-6077-A-003-A	Hallway (Media Center)	4/15/2022	4/19/2022	A2D0614-04	Lead	ND	0.2	15	ppb
154-DF-6079-A-003-A	Hallway (Main Office)	4/15/2022	4/19/2022	A2D0614-05	Lead	ND	0.2	15	ppb
154-DF-6080-A-003-A	Hallway (Classroom 315)	4/15/2022	4/19/2022	A2D0614-06	Lead	ND	0.2	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb

Page 1 of 1