

Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Ockley Green Middle School - Test 5

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
178-DF-2748-A-005-A	Hallway (207)	8/25/2021	8/26/2021	A1H0836-35	Lead	0.685	0.2	15	ppb
178-DF-5819-N/A-005-A	Health Room	8/25/2021	8/26/2021	A1H0836-36	Lead	2.75	0.2	15	ppb
178-DF-2751-A-005-A	Hallway (215)	8/25/2021	8/26/2021	A1H0836-37	Lead	ND	0.2	15	ppb
178-DF-2730-N/A-005-A	Staff Room	8/25/2021	8/26/2021	A1H0836-38	Lead	1.79	0.2	15	ppb
178-DF-2733-A-005-A	Hallway (105)	8/25/2021	8/26/2021	A1H0836-39	Lead	ND	0.2	15	ppb
178-DF-2745-A-005-A	Hallway (115)	8/25/2021	8/26/2021	A1H0836-40	Lead	0.213	0.2	15	ppb
178-DF-2753-A-005-A	Hallway (310)	8/25/2021	8/26/2021	A1H0836-41	Lead	ND	0.2	15	ppb
178-DF-2749-A-005-A	Cafeteria	8/25/2021	8/26/2021	A1H0836-42	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb