

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Ockley Green Middle School - Test 6**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
178-DF-5818-A-006-A	Kitchen	9/30/2021	10/5/2021	A1J0003-19	Lead	0.576	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb