

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Ockley Green - Test 8**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
178-DF-2730-N/A-008-A	Staff Room	6/7/2022	6/16/2022	A2F0240-09	Lead	2.29	0.200	15	ppb
178-DF-2733-A-008-A	Hallway (1004)	6/7/2022	6/16/2022	A2F0240-04	Lead	ND	0.200	15	ppb
178-DF-2745-A-008-A	Hallway (1014)	6/7/2022	6/16/2022	A2F0240-06	Lead	ND	0.200	15	ppb
178-DF-2748-A-008-A	Hallway (207)	6/7/2022	6/16/2022	A2F0240-02	Lead	ND	0.200	15	ppb
178-DF-2749-A-008-A	Cafeteria	6/7/2022	6/16/2022	A2F0240-03	Lead	ND	0.200	15	ppb
178-DF-2751-A-008-A	Hallway (215)	6/7/2022	6/16/2022	A2F0240-01	Lead	ND	0.200	15	ppb
178-DF-2753-A-008-A	Hallway (1021)	6/7/2022	6/16/2022	A2F0240-05	Lead	ND	0.200	15	ppb
178-DF-5818-N/A-008-A	Kitchen	6/7/2022	6/16/2022	A2F0240-07	Lead	0.947	0.200	15	ppb
178-DF-5819-N/A-008-A	Health Room	6/7/2022	6/16/2022	A2F0240-08	Lead	4.50	0.200	15	ppb

Analyzed by: Apex Laboratories

*OHA Action Level = 15ppb

Reviewed by: PBS Engineering and Environmental

Page 1 of 1



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Monday, June 20, 2022

Joel McCarthy
PBS Engineering and Environmental
4412 S Corbett Ave
Portland, OR 97239

RE: A2F0240 - Portland Public Schools - Oakley Green MS/25000.219

Thank you for using Apex Laboratories. We greatly appreciate your business and strive to provide the highest quality services to the environmental industry.

Enclosed are the results of analyses for work order A2F0240, which was received by the laboratory on 6/7/2022 at 1:28:00PM.

If you have any questions concerning this report or the services we offer, please feel free to contact me by email at: jwoodcock@apex-labs.com, or by phone at 503-718-2323.

Please note: All samples will be disposed of within 30 days of sample receipt, unless prior arrangements have been made.

Cooler Receipt Information

(See Cooler Receipt Form for details)

Cooler #1	21.7 degC
-----------	-----------

This Final Report is the official version of the data results for this sample submission, unless superseded by a subsequent, labeled amended report.

All other deliverables derived from this data, including Electronic Data Deliverables (EDDs), CLP-like forms, client requested summary sheets, and all other products are considered secondary to this report.



Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Jason Woodcock, Project Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

PBS Engineering and Environmental

4412 S Corbett Ave
Portland, OR 97239

Project: **Portland Public Schools**

Project Number: **Oakley Green MS/25000.21**

Project Manager: **Joel McCarthy**

Report ID:

A2F0240 - 06 20 22 1419

ANALYTICAL REPORT FOR SAMPLES

SAMPLE INFORMATION

Client Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
178-DF-2751-A-008-A	A2F0240-01	Drinking Water	06/07/22 00:00	06/07/22 13:28
178-DF-2748-A-008-A	A2F0240-02	Drinking Water	06/07/22 00:00	06/07/22 13:28
178-DF-2749-A-008-A	A2F0240-03	Drinking Water	06/07/22 00:00	06/07/22 13:28
178-DF-2733-A-008-A	A2F0240-04	Drinking Water	06/07/22 00:00	06/07/22 13:28
178-DF-2753-A-008-A	A2F0240-05	Drinking Water	06/07/22 00:00	06/07/22 13:28
178-DF-2745-A-008-A	A2F0240-06	Drinking Water	06/07/22 00:00	06/07/22 13:28
178-DF-5818-NA-008-A	A2F0240-07	Drinking Water	06/07/22 00:00	06/07/22 13:28
178-DF-5819-NA-008-A	A2F0240-08	Drinking Water	06/07/22 00:00	06/07/22 13:28
178-DF-2730-NA-008-A	A2F0240-09	Drinking Water	06/07/22 00:00	06/07/22 13:28

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Jason Woodcock, Project Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street

Tigard, OR 97223

503-718-2323

ORELAP ID: OR100062

PBS Engineering and Environmental

4412 S Corbett Ave

Portland, OR 97239

Project: Portland Public SchoolsProject Number: Oakley Green MS/25000.21Project Manager: Joel McCarthy

Report ID:

A2F0240 - 06 20 22 1419

ANALYTICAL SAMPLE RESULTS

Total Metals in Drinking Water by EPA 200.8 (ICPMS)

Analyte	Sample Result	Detection Limit	Reporting Limit	Units	Dilution	Date Analyzed	Method Ref.	Notes
178-DF-2751-A-008-A (A2F0240-01)				Matrix: Drinking Water				
Batch: 22F0568								
Lead	ND	---	0.200	ug/L	1	06/16/22 19:47	EPA 200.8	
178-DF-2748-A-008-A (A2F0240-02)				Matrix: Drinking Water				
Batch: 22F0568								
Lead	ND	---	0.200	ug/L	1	06/16/22 19:58	EPA 200.8	
178-DF-2749-A-008-A (A2F0240-03)				Matrix: Drinking Water				
Batch: 22F0568								
Lead	ND	---	0.200	ug/L	1	06/16/22 20:01	EPA 200.8	
178-DF-2733-A-008-A (A2F0240-04)				Matrix: Drinking Water				
Batch: 22F0568								
Lead	ND	---	0.200	ug/L	1	06/16/22 20:04	EPA 200.8	
178-DF-2753-A-008-A (A2F0240-05)				Matrix: Drinking Water				
Batch: 22F0568								
Lead	ND	---	0.200	ug/L	1	06/16/22 20:08	EPA 200.8	
178-DF-2745-A-008-A (A2F0240-06)				Matrix: Drinking Water				
Batch: 22F0568								
Lead	ND	---	0.200	ug/L	1	06/16/22 20:11	EPA 200.8	
178-DF-5818-NA-008-A (A2F0240-07)				Matrix: Drinking Water				
Batch: 22F0568								
Lead	0.947	---	0.200	ug/L	1	06/16/22 20:15	EPA 200.8	
178-DF-5819-NA-008-A (A2F0240-08)				Matrix: Drinking Water				
Batch: 22F0568								
Lead	4.50	---	0.200	ug/L	1	06/16/22 20:19	EPA 200.8	
178-DF-2730-NA-008-A (A2F0240-09)				Matrix: Drinking Water				
Batch: 22F0574								
Lead	2.29	---	0.200	ug/L	1	06/16/22 20:46	EPA 200.8	

Apex Laboratories

Jason Woodcock, Project Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street

Tigard, OR 97223

503-718-2323

ORELAP ID: OR100062

PBS Engineering and Environmental

4412 S Corbett Ave

Portland, OR 97239

Project: Portland Public SchoolsProject Number: Oakley Green MS/25000.21Project Manager: Joel McCarthy

Report ID:

A2F0240 - 06 20 22 1419

QUALITY CONTROL (QC) SAMPLE RESULTS

Total Metals in Drinking Water by EPA 200.8 (ICPMS)

Analyte	Result	Detection Limit	Reporting Limit	Units	Dilution	Spike Amount	Source Result	% REC	% REC Limits	RPD	RPD Limit	Notes
Batch 22F0568 - EPA 200.8 Direct Analysis							Drinking Water					
Blank (22F0568-BLK1)		Prepared: 06/15/22 18:38		Analyzed: 06/16/22 18:36								
<u>EPA 200.8</u>												
Lead	ND	---	0.200	ug/L	1	---	---	---	---	---	---	
LCS (22F0568-BS1)		Prepared: 06/15/22 18:38		Analyzed: 06/16/22 18:39								
<u>EPA 200.8</u>												
Lead	13.8	---	0.201	ug/L	1	15.0	---	92	85 - 115%	---	---	
Matrix Spike (22F0568-MS2)		Prepared: 06/15/22 18:38		Analyzed: 06/16/22 20:23								
<u>QC Source Sample: 178-DF-5819-NA-008-A (A2F0240-08)</u>												
<u>EPA 200.8</u>												
Lead	18.0	---	0.201	ug/L	1	15.0	4.50	90	70 - 130%	---	---	
Batch 22F0574 - EPA 200.8 Direct Analysis							Drinking Water					
Blank (22F0574-BLK1)		Prepared: 06/16/22 08:18		Analyzed: 06/16/22 20:31								
<u>EPA 200.8</u>												
Lead	ND	---	0.200	ug/L	1	---	---	---	---	---	---	
LCS (22F0574-BS1)		Prepared: 06/16/22 08:18		Analyzed: 06/16/22 20:42								
<u>EPA 200.8</u>												
Lead	13.8	---	0.201	ug/L	1	15.0	---	92	85 - 115%	---	---	
Duplicate (22F0574-DUP1)		Prepared: 06/16/22 08:18		Analyzed: 06/16/22 20:50								
<u>QC Source Sample: 178-DF-2730-NA-008-A (A2F0240-09)</u>												
<u>EPA 200.8</u>												
Lead	2.32	---	0.200	ug/L	1	---	2.29	---	---	2	20%	
Matrix Spike (22F0574-MS1)		Prepared: 06/16/22 08:18		Analyzed: 06/16/22 20:54								
<u>QC Source Sample: 178-DF-2730-NA-008-A (A2F0240-09)</u>												
<u>EPA 200.8</u>												
Lead	15.7	---	0.201	ug/L	1	15.0	2.29	89	70 - 130%	---	---	

Apex Laboratories

Jason Woodcock, Project Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

**ANALYTICAL REPORT****Apex Laboratories, LLC**

6700 S.W. Sandburg Street

Tigard, OR 97223

503-718-2323

ORELAP ID: OR100062

PBS Engineering and Environmental

4412 S Corbett Ave

Portland, OR 97239

Project: **Portland Public Schools**Project Number: **Oakley Green MS/25000.21'**Project Manager: **Joel McCarthy****Report ID:****A2F0240 - 06 20 22 1419****SAMPLE PREPARATION INFORMATION****Total Metals in Drinking Water by EPA 200.8 (ICPMS)****Prep: EPA 200.8 Direct Analysis**

Lab Number	Matrix	Method	Sampled	Prepared	Sample Initial/Final	Default Initial/Final	RL Prep Factor
<u>Batch: 22F0568</u>							
A2F0240-01	Drinking Water	EPA 200.8	06/07/22 00:00	06/15/22 18:38	10mL/10mL	10mL/10mL	1.00
A2F0240-02	Drinking Water	EPA 200.8	06/07/22 00:00	06/15/22 18:38	10mL/10mL	10mL/10mL	1.00
A2F0240-03	Drinking Water	EPA 200.8	06/07/22 00:00	06/15/22 18:38	10mL/10mL	10mL/10mL	1.00
A2F0240-04	Drinking Water	EPA 200.8	06/07/22 00:00	06/15/22 18:38	10mL/10mL	10mL/10mL	1.00
A2F0240-05	Drinking Water	EPA 200.8	06/07/22 00:00	06/15/22 18:38	10mL/10mL	10mL/10mL	1.00
A2F0240-06	Drinking Water	EPA 200.8	06/07/22 00:00	06/15/22 18:38	10mL/10mL	10mL/10mL	1.00
A2F0240-07	Drinking Water	EPA 200.8	06/07/22 00:00	06/15/22 18:38	10mL/10mL	10mL/10mL	1.00
A2F0240-08	Drinking Water	EPA 200.8	06/07/22 00:00	06/15/22 18:38	10mL/10mL	10mL/10mL	1.00
<u>Batch: 22F0574</u>							
A2F0240-09	Drinking Water	EPA 200.8	06/07/22 00:00	06/16/22 08:18	10mL/10mL	10mL/10mL	1.00

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Jason Woodcock, Project Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street

Tigard, OR 97223

503-718-2323

ORELAP ID: OR100062

PBS Engineering and Environmental

4412 S Corbett Ave

Portland, OR 97239

Project: Portland Public Schools

Project Number: Oakley Green MS/25000.21

Project Manager: Joel McCarthy

Report ID:

A2F0240 - 06 20 22 1419

QUALIFIER DEFINITIONS

Client Sample and Quality Control (QC) Sample Qualifier Definitions:

There are No Qualifiers on Sample or QC Data for this report

Apex Laboratories

A handwritten signature in black ink, appearing to read "J. Woodcock", written over a light gray rectangular background.

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Jason Woodcock, Project Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

PBS Engineering and Environmental

4412 S Corbett Ave
Portland, OR 97239

Project: **Portland Public Schools**

Project Number: **Oakley Green MS/25000.21**
Project Manager: **Joel McCarthy**

Report ID:

A2F0240 - 06 20 22 1419

REPORTING NOTES AND CONVENTIONS:

Abbreviations:

DET Analyte DETECTED at or above the detection or reporting limit.
ND Analyte NOT DETECTED at or above the detection or reporting limit.
NR Result Not Reported.
RPD Relative Percent Difference. RPDs for Matrix Spikes and Matrix Spike Duplicates are based on concentration, not recovery.

Detection Limits: Limit of Detection (LOD)

Limits of Detection (LODs) are normally set at a level of one half the validated Limit of Quantitation (LOQ).
If no value is listed ('-----'), then the data has not been evaluated below the Reporting Limit.

Reporting Limits: Limit of Quantitation (LOQ)

Validated Limits of Quantitation (LOQs) are reported as the Reporting Limits for all analyses where the LOQ, MRL, PQL or CRL are requested. The LOQ represents a level at or above the low point of the calibration curve, that has been validated according to Apex Laboratories' comprehensive LOQ policies and procedures.

Reporting Conventions:

Basis: Results for soil samples are generally reported on a 100% dry weight basis.
The Result Basis is listed following the units as "dry", "wet", or " " (blank) designation.

"dry" Sample results and Reporting Limits are reported on a dry weight basis. (i.e. "ug/kg dry")
See Percent Solids section for details of dry weight analysis.

"wet" Sample results and Reporting Limits for this analysis are normally dry weight corrected, but have not been modified in this case.

" " Results without 'wet' or 'dry' designation are not normally dry weight corrected. These results are considered 'As Received'.

QC Source:

In cases where there is insufficient sample provided for Sample Duplicates and/or Matrix Spikes, a Lab Control Sample Duplicate (LCS Dup) may be analyzed to demonstrate accuracy and precision of the extraction batch.

Non-Client Batch QC Samples (Duplicates and Matrix Spike/Duplicates) are not included in this report. Please request a Full QC report if this data is required.

Miscellaneous Notes:

" --- " QC results are not applicable. For example, % Recoveries for Blanks and Duplicates, % RPD for Blanks, Blank Spikes and Matrix Spikes, etc.

" *** " Used to indicate a possible discrepancy with the Sample and Sample Duplicate results when the %RPD is not available. In this case, either the Sample or the Sample Duplicate has a reportable result for this analyte, while the other is Non Detect (ND).

Blanks:

Standard practice is to evaluate the results from Blank QC Samples down to a level equal to ½ the Reporting Limit (RL).
-For Blank hits falling between ½ the RL and the RL (J flagged hits), the associated sample and QC data will receive a 'B-02' qualifier.
-For Blank hits above the RL, the associated sample and QC data will receive a 'B' qualifier, per Apex Laboratories' Blank Policy.
For further details, please request a copy of this document.

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Jason Woodcock, Project Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

PBS Engineering and Environmental

4412 S Corbett Ave
Portland, OR 97239

Project: **Portland Public Schools**

Project Number: **Oakley Green MS/25000.21**
Project Manager: **Joel McCarthy**

Report ID:

A2F0240 - 06 20 22 1419

REPORTING NOTES AND CONVENTIONS (Cont.):

Blanks (Cont.):

Sample results flagged with a 'B' or 'B-02' qualifier are potentially biased high if the sample results are less than ten times the level found in the blank for inorganic analyses, or less than five times the level found in the blank for organic analyses.

'B' and 'B-02' qualifications are only applied to sample results detected above the Reporting Level.

Preparation Notes:

Mixed Matrix Samples:

Water Samples:

Water samples containing significant amounts of sediment are decanted or separated prior to extraction, and only the water portion analyzed, unless otherwise directed by the client.

Soil and Sediment Samples:

Soil and Sediment samples containing significant amounts of water are decanted prior to extraction, and only the solid portion analyzed, unless otherwise directed by the client.

Sampling and Preservation Notes:

Certain regulatory programs, such as National Pollutant Discharge Elimination System (NPDES), require that activities such as sample filtration (for dissolved metals, orthophosphate, hexavalent chromium, etc.) and testing of short hold analytes (pH, Dissolved Oxygen, etc.) be performed in the field (on-site) within a short time window. In addition, sample matrix spikes are required for some analyses, and sufficient volume must be provided, and billable site specific QC requested, if this is required. All regulatory permits should be reviewed to ensure that these requirements are being met.

Data users should be aware of which regulations pertain to the samples they submit for testing. If related sample collection activities are not approved for a particular regulatory program, results should be considered estimates. Apex Laboratories will qualify these analytes according to the most stringent requirements, however results for samples that are for non-regulatory purposes may be acceptable.

Samples that have been filtered and preserved at Apex Laboratories per client request are listed in the preparation section of the report with the date and time of filtration listed.

Apex Laboratories maintains detailed records on sample receipt, including client label verification, cooler temperature, sample preservation, hold time compliance and field filtration. Data is qualified as necessary, and the lack of qualification indicates compliance with required parameters.

Apex Laboratories

Jason Woodcock, Project Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

PBS Engineering and Environmental

4412 S Corbett Ave
Portland, OR 97239

Project: **Portland Public Schools**

Project Number: **Oakley Green MS/25000.21'**

Project Manager: **Joel McCarthy**

Report ID:

A2F0240 - 06 20 22 1419

LABORATORY ACCREDITATION INFORMATION

ORELAP Certification ID: OR100062 (Primary Accreditation)

EPA ID: OR01039

All methods and analytes reported from work performed at Apex Laboratories are included on Apex Laboratories' ORELAP Scope of Certification, with the exception of any analyte(s) listed below:

Apex Laboratories

Matrix	Analysis	TNI_ID	Analyte	TNI_ID	Accreditation
<u>All reported analytes are included in Apex Laboratories' current ORELAP scope.</u>					

Secondary Accreditations

Apex Laboratories also maintains reciprocal accreditation with non-TNI states (Washington DOE), as well as other state specific accreditations not listed here.

Subcontract Laboratory Accreditations

Subcontracted data falls outside of Apex Laboratories' Scope of Accreditation.

Please see the Subcontract Laboratory report for full details, or contact your Project Manager for more information.

Field Testing Parameters

Results for Field Tested data are provided by the client or sampler, and fall outside of Apex Laboratories' Scope of Accreditation.

Apex Laboratories

Jason Woodcock, Project Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street

Tigard, OR 97223

503-718-2323

ORELAP ID: OR100062

PBS Engineering and Environmental

4412 S Corbett Ave

Portland, OR 97239

Project: Portland Public SchoolsProject Number: Oakley Green MS/25000.21'Project Manager: Joel McCarthy

Report ID:

A2F0240 - 06 20 22 1419

APEX LABS 6700 SW Sandburg St., Tigard, OR 97223 Ph: 503-718-2323		CHAIN OF CUSTODY		Lab # <u>A2F0240</u> of <u>1</u>	
Company: PBS Eng. & Env. Address: 4412 S Corbett Ave, Portland, OR 97239		Project Mgr: <u>Joel McCarthy</u> Phone: <u>971.284.7762</u>		Project Name: <u>Oakley Green MS</u> Email: <u>joel.mccarthy@pbsusa.com</u> PO # <u>25000.219</u>	
Sampled by: <u>Taylor Cook</u>		ANALYSIS REQUEST			
Site Location: <u>OR</u> <u>WA</u> <u>CA</u> <u>AK</u> ID <u>—</u>					
LAB ID #		DATE	TIME	MATRIX	# OF CONTAINERS
SAMPLE ID					
178-DF-2751-A-008-A	10/7	1033			
178-DF-2748-A-008-A	10/7	1027			
178-DF-2749-A-008-A	10/7	1010			
178-DF-2783-A-008-A	10/7	1022			
178-DF-2753-A-008-A	10/7	1037			
178-DF-2745-A-008-A	10/7	1042			
178-DF-5818-NA-1008-A	10/7	1013			
178-DF-5819-NA-1008-A	10/7	1045			
178-DF-2730-NA-1008-A	10/7	1040			
SPECIAL INSTRUCTIONS:					
Normal Turn Around Time (TAT) = 10 Business Days					
TAT Requested (circle) 1 Day 2 Day 3 Day 4 DAY 5 DAY Other: <u>10 day</u>					
SAMPLES ARE HELD FOR 30 DAYS					
RELINQUISHED BY:		RECEIVED BY:		RECEIVED BY:	
Signature: <u>[Signature]</u>		Signature: <u>[Signature]</u>		Signature: <u>[Signature]</u>	
Date: <u>10/7/2020</u>		Date: <u>10/7/2020</u>		Date: <u>10/7/2020</u>	
Printed Name: <u>Taylor Cook</u>		Printed Name: <u>Shawn Thompson</u>		Printed Name: <u>Shawn Thompson</u>	
Time: <u>1020</u>		Time: <u>1328</u>		Time: <u>1328</u>	
Company: <u>PBS</u>		Company: <u>Apex</u>		Company: <u>Apex</u>	

Apex Laboratories

Jason Woodcock, Project Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

PBS Engineering and Environmental

4412 S Corbett Ave

Portland, OR 97239

Project: Portland Public Schools

Project Number: Oakley Green MS/25000.21

Project Manager: Joel McCarthy

Report ID:

A2F0240 - 06 20 22 1419

APEX LABS COOLER RECEIPT FORM

Client: PBS Element WO#: A2 F0240

Project/Project #: Oakley Green MS

Delivery Info:

Date/time received: 6-7-22 @ 1328 By: SAT

Delivered by: Apex Client ESS FedEx UPS Swift Senvoy SDS Other

Cooler Inspection Date/time inspected: 6-7-22 @ 1421 By: SAT

Chain of Custody included? Yes X No Custody seals? Yes No X

Signed/dated by client? Yes X No

Signed/dated by Apex? Yes X No

Cooler #1 Cooler #2 Cooler #3 Cooler #4 Cooler #5 Cooler #6 Cooler #7

Temperature (°C) 21.7

Received on ice? (Y/N) N

Temp. blanks? (Y/N) N

Ice type: (Gel/Real/Other) N/A

Condition: Good

Cooler out of temp? (Y/N) Possible reason why: Drinking Water

Green dots applied to out of temperature samples? Yes X

Out of temperature samples form initiated? Yes X

Sample Inspection: Date/time inspected: 6-8-22 @ 1141 By: DJS

All samples intact? Yes X No Comments:

Bottle labels/COCs agree? Yes X No Comments:

COC/container discrepancies form initiated? Yes No X

Containers/volumes received appropriate for analysis? Yes X No Comments:

Do VOA vials have visible headspace? Yes No NA X

Comments:

Water samples: pH checked: Yes X No NA pH appropriate? Yes X No NA

Comments:

Additional information:

Labeled by: Witness: Cooler Inspected by:

DJS

b

DJS