

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Pioneer Program at Youngson 5-9 - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
298-DF-5964-N/A-004-A	Kitchen	7/14/2021	07/20/2021	A1G0437-14	Lead	0.885	0.2	15	ppb
298-DF-1322-A-004-A	Cafeteria	7/14/2021	07/20/2021	A1G0437-15	Lead	0.224	0.2	15	ppb
298-DF-5965-N/A-004-A	Life Skills	7/14/2021	07/20/2021	A1G0437-16	Lead	0.398	0.2	15	ppb
298-DF-5967-N/A-004-A	Staff Room	7/14/2021	07/20/2021	A1G0437-17	Lead	3.83	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb

Page 1 of 1