

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Rigler Elementary School - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
276-DF-5846-N/A-005-A	Kitchen	2/5/2021	2/9/2021	A1B0229-01	Lead	0.474	0.2	15	ppb
276-DF-1628-A-005-A	Cafeteria	2/5/2021	2/9/2021	A1B0229-02	Lead	ND	0.2	15	ppb
276-DF-1627-A-005-A	Hallway (18)	2/5/2021	2/9/2021	A1B0229-03	Lead	ND	0.2	15	ppb
276-DF-1633-A-005-A	Sun School	2/5/2021	2/9/2021	A1B0229-04	Lead	ND	0.2	15	ppb
276-DF-5848-A-005-A	Staff Room	2/5/2021	2/9/2021	A1B0229-05	Lead	0.472	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb