

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Rosa Parks Elementary School - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
175-DF-5794-A-006-A	Hallway (Work Room)	9/30/2021	10/5/2021	A1J0003-13	Lead	ND	0.2	15	ppb
175-DF-5793-A-006-A	Cafeteria	9/30/2021	10/5/2021	A1J0003-14	Lead	ND	0.2	15	ppb
175-DF-2903-A-006-A	Hallway (Resource Room)	9/30/2021	10/5/2021	A1J0003-15	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb