

Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Scott Elementary School - Test 4

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
282-DF-5833-A-004-A	Portable Hallway	05/26/2021	06/08/2021	A1E1233-01	Lead	ND	0.2	15	ppb
282-DF-2208-A-004-A	Portable Music Room	05/26/2021	06/08/2021	A1E1233-02	Lead	ND	0.2	15	ppb
282-DF-2178-A-004-A	Hallway (51)	05/26/2021	06/08/2021	A1E1233-03	Lead	ND	0.2	15	ppb
282-DF-2199-A-004-A	Hallway (202)	05/26/2021	06/08/2021	A1E1233-04	Lead	ND	0.2	15	ppb
282-DF-5837-A-004-A	Hallway (302)	05/26/2021	06/08/2021	A1E1233-05	Lead	ND	0.2	15	ppb
282-DF-6511-NA-004-A	Kitchen	05/26/2021	06/08/2021	A1E1233-06	Lead	2.39	0.2	15	ppb
282-DF-2172-A-004-A	Cafeteria	05/26/2021	06/08/2021	A1E1233-07	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb