

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Scott Elementary School - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
282-DF-2192-A-005-A	Corridor (209)	10/1/2021	10/5/2021	A1J0022-03	Lead	ND	0.2	15	ppb
282-DF-5836-N/A-005-A	Health Room	10/1/2021	10/5/2021	A1J0022-04	Lead	0.462	0.2	15	ppb
282-DF-5834-N/A-005-A	Staff Room	10/1/2021	10/5/2021	A1J0022-05	Lead	0.558	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb