

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Sellwood Middle School - Test 6**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
283-DF-5997-N/A-006-A	Staff Room	8/27/2021	8/31/2021	A1H0917-31	Lead	1.85	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb