

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Sellwood Middle School - Test 7**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
283-DF-1248-A-006-A	Hallway (Classroom 207)	10/7/2021	10/11/2021	A1J0309-03	Lead	ND	0.2	15	ppb
283-DF-1247-A-006-A	Hallway (Classroom 309)	10/7/2021	10/11/2021	A1J0309-04	Lead	1.07	0.2	15	ppb
283-DF-1252-A-006-A	Hallway (Classroom 323)	10/7/2021	10/11/2021	A1J0309-05	Lead	ND	0.2	15	ppb
283-DF-1249-A-006-A	Hallway (Classroom 229)	10/7/2021	10/11/2021	A1J0309-06	Lead	ND	0.2	15	ppb
283-DF-1288-A-006-A	Hallway (Classroom 121)	10/7/2021	10/11/2021	A1J0309-07	Lead	ND	0.2	15	ppb
283-DF-1431-A-006-A	Hallway (Classroom 135)	10/7/2021	10/11/2021	A1J0309-08	Lead	ND	0.2	15	ppb
283-DF-1297-A-006-A	Cafeteria	10/7/2021	10/11/2021	A1J0309-09	Lead	ND	0.2	15	ppb
283-DF-5998-N/A-006-A	Kitchen	10/7/2021	10/11/2021	A1J0309-10	Lead	ND	0.2	15	ppb
283-DF-1296-A-006-A	Hallway (Classroom 105)	10/7/2021	10/11/2021	A1J0309-11	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb

Page 1 of 1