

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Sitton Elementary - Test 4**

| Sample Identification # | Location     | Date/Time Collected | Date Analyzed | Lab ID     | Analyte | Results | Detection Limit | PPS Action Level* | Units |
|-------------------------|--------------|---------------------|---------------|------------|---------|---------|-----------------|-------------------|-------|
| 184-DF-2713-N/A-004-A   | ISC Room 7   | 8/25/2021           | 08/26/2021    | A1H0836-10 | Lead    | 2.26    | 0.2             | 15                | ppb   |
| 184-DF-2717-N/A-004-A   | Headstart 16 | 8/25/2021           | 08/26/2021    | A1H0836-11 | Lead    | 1.23    | 0.2             | 15                | ppb   |
| 184-DF-5803-N/A-004-A   | Kitchen      | 8/25/2021           | 08/26/2021    | A1H0836-12 | Lead    | ND      | 0.2             | 15                | ppb   |
| 184-DF-2714-N/A-004-A   | Headstart 15 | 8/25/2021           | 08/26/2021    | A1H0836-13 | Lead    | 1.22    | 0.2             | 15                | ppb   |
| 184-DF-2708-N/A-004-A   | ISC Room 13  | 8/25/2021           | 08/26/2021    | A1H0836-14 | Lead    | 2.69    | 0.2             | 15                | ppb   |
| 184-DF-5802-N/A-004-A   | Staff Room   | 8/25/2021           | 08/26/2021    | A1H0836-15 | Lead    | 0.719   | 0.2             | 15                | ppb   |

Analyzed by: Apex Laboratories  
Reviewed by: PSI-Intertek

\*OHA Action Level = 15ppb