

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Sitton Elementary School - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
184-DF-2756-A-005-A	Hallway (Classroom 5)	9/30/2021	10/5/2021	A1J0003-11	Lead	ND	0.2	15	ppb
184-DF-2731-A-005-A	Hallway (Staff Room)	9/30/2021	10/5/2021	A1J0003-17	Lead	ND	0.2	15	ppb
184-DF-2720-A-005-A	Hallway (Classroom 17)	9/30/2021	10/5/2021	A1J0003-18	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb