

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Terwilliger Site - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
366-DF6445-NA-004-A	Kitchen 19	12/29/2022	12/30/2022	A2L1053-02	Lead	1.51	0.2	15	ppb
366-DF6446-NA-004-A	Health Room 6B	12/29/2022	12/30/2022	A2L1053-03	Lead	5.89	0.2	15	ppb
366-DF6447-A-004-A	Outside Annex (Classroo	12/29/2022	12/30/2022	A2L1053-01	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories

*OHA Action Level = 15ppb

Reviewed by: PBS Engineering and Environmental

Page 1 of 1