

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Terwilliger Site - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
366-DF-6446-NA-005-A	Health Room 6B	2/7/2023	2/10/2023	A3B0283-01	Lead	0.355	0.2	15	ppb

Analyzed by: Apex Laboratories

*OHA Action Level = 15ppb

Reviewed by: PBS Engineering and Environmental

Page 1 of 1