

Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Vernon Elementary School - Test 4

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
284-DF-5797-N/A-004-A	Kitchen	9/11/2020	9/15/2020	A0I0302-22	Lead	ND	0.2	15	ppb
284-DF-1769-A-004-A	Cafeteria	9/11/2020	9/16/2020	A0I0302-23	Lead	0.258	0.2	15	ppb
284-DF-1689-A-004-A	Hallway (103)	9/11/2020	9/17/2020	A0I0302-24	Lead	ND	0.2	15	ppb
284-DF-1760-A-004-A	Hallway (Gym)	9/11/2020	9/18/2020	A0I0302-25	Lead	ND	0.2	15	ppb
284-DF-1759-A-004-A	Hallway (Library)	9/11/2020	9/19/2020	A0I0302-26	Lead	ND	0.2	15	ppb
284-DF-1695-A-004-A	Hallway (116)	9/11/2020	9/20/2020	A0I0302-27	Lead	1.45	0.2	15	ppb
284-DF-1686-A-004-A	Hallway (108)	9/11/2020	9/21/2020	A0I0302-28	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb