

Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Vestal Elementary School - Test 4

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
286-DF-5857-A-004-A	Portable Child Care	2/5/2021	2/9/2021	A1B0229-06	Lead	ND	0.2	15	ppb
286-DF-5856-N/A-004-A	Kitchen	2/5/2021	2/9/2021	A1B0229-07	Lead	0.768	0.2	15	ppb
286-DF-5445-N/A-004-A	Staff Room	2/5/2021	2/9/2021	A1B0229-08	Lead	0.292	0.2	15	ppb
286-DF-5442-N/A-004-A	ISC	2/5/2021	2/9/2021	A1B0229-09	Lead	0.504	0.2	15	ppb
286-DF-5436-A-004-A	Hallway (110)	2/5/2021	2/9/2021	A1B0229-10	Lead	ND	0.2	15	ppb
286-DF-5455-A-004-A	Hallway (214)	2/5/2021	2/9/2021	A1B0229-11	Lead	ND	0.2	15	ppb
286-DF-5495-A-004-A	Hallway (202)	2/5/2021	2/9/2021	A1B0229-12	Lead	ND	0.2	15	ppb
286-DF-5446-A-004-A	Hallway (102)	2/5/2021	2/9/2021	A1B0229-13	Lead	ND	0.2	15	ppb
286-DF-5854-A-004-A	Entrance	2/5/2021	2/9/2021	A1B0229-14	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb