

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Winterhaven Elementary School - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
239-DF-6016-N/A-005-A	Health Room	4/6/2022	4/12/2022	A2D0232-01	Lead	0.38	0.2	15	ppb
239-DF-6017-N/A-005-A	Staff Room	4/6/2022	4/12/2022	A2D0232-02	Lead	0.56	0.2	15	ppb
239-DF-6019-N/A-005-A	Staff Room	4/6/2022	4/12/2022	A2D0232-03	Lead	0.67	0.2	15	ppb

Analyzed by: Apex Laboratories

*OHA Action Level = 15ppb

Reviewed by: PBS Engineering and Environmental, Inc.

Page 1 of 1