

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Woodlawn Elementary - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
294-DF-3045-N/A-004-A	Health Room	8/25/2021	8/26/2021	A1H0836-24	Lead	0.845	0.2	15	ppb
294-DF-3036-N/A-004-A	Portable	8/25/2021	8/26/2021	A1H0836-25	Lead	0.582	0.2	15	ppb
294-DF-3046-A-004-A	Hallway (212)	8/25/2021	8/26/2021	A1H0836-26	Lead	ND	0.2	15	ppb
294-DF-5817-N/A-004-A	Staff Room 213	8/25/2021	8/26/2021	A1H0836-27	Lead	0.368	0.2	15	ppb
294-DF-5816-A-004-A	Hallway (130)	8/25/2021	8/26/2021	A1H0836-28	Lead	0.288	0.2	15	ppb
294-DF-3043-A-004-A	Hallway (250 A)	8/25/2021	8/26/2021	A1H0836-29	Lead	ND	0.2	15	ppb
294-DF-3034-N/A-004-A	Portable	8/25/2021	8/26/2021	A1H0836-30	Lead	0.702	0.2	15	ppb
294-DF-3033-A-004-A	Daycare	8/25/2021	8/26/2021	A1H0836-31	Lead	ND	0.2	15	ppb
294-DF-3040-A-004-A	Hallway (154)	8/25/2021	8/26/2021	A1H0836-32	Lead	ND	0.2	15	ppb
294-DF-6512-N/A-004-A	Kitchen	8/25/2021	8/26/2021	A1H0836-33	Lead	ND	0.2	15	ppb
294-DF-3050-A-004-A	Hallway (113)	8/25/2021	8/26/2021	A1H0836-34	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb

Page 1 of 1