

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Woodmere Site - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
296-DF5943-NA-005-A	Pre-K	12/29/2022	12/30/2022	A2L1051-03	Lead	0.611	0.2	15	ppb
296-DF5936-NA-005-A	Kitchen	12/29/2022	12/30/2022	A2L1051-02	Lead	0.443	0.2	15	ppb
296-DF5939-A-005-A	Hallway (Kindergarten 1	12/29/2022	12/30/2022	A2L1051-01	Lead	0.621	0.2	15	ppb

Analyzed by: Apex Laboratories

*OHA Action Level = 15ppb

Reviewed by: PBS Engineering and Environmental

Page 1 of 1