

Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Arleta (232) - Pilot Week 2

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
232-CH-5220-A-PP02-A	Hallway (17)	9/6/2019	9/11/2019	A9I0145-01	Lead	0.2	0.20	15	ppb
232-CH-5220-B-PP02-A	Hallway (17)	9/6/2019	9/11/2019	A9I0145-02	Lead	ND	0.20	15	ppb
232-CH-5220-C-PP02-A	Hallway (17)	9/6/2019	9/11/2019	A9I0145-03	Lead	ND	0.20	15	ppb
232-CH-5225-A-PP02-A	Hallway (7)	9/6/2019	9/11/2019	A9I0145-04	Lead	ND	0.20	15	ppb
232-CH-5225-B-PP02-A	Hallway (7)	9/6/2019	9/11/2019	A9I0145-05	Lead	ND	0.20	15	ppb
232-CH-5225-C-PP02-A	Hallway (7)	9/6/2019	9/11/2019	A9I0145-06	Lead	ND	0.20	15	ppb
232-CH-5234-A-PP02-A	Hallway (3)	9/6/2019	9/11/2019	A9I0145-07	Lead	ND	0.20	15	ppb
232-CH-5234-B-PP02-A	Hallway (3)	9/6/2019	9/11/2019	A9I0145-08	Lead	ND	0.20	15	ppb
232-CH-5234-C-PP02-A	Hallway (3)	9/6/2019	9/11/2019	A9I0145-09	Lead	ND	0.20	15	ppb
232-CH-5238-A-PP02-A	Hallway (40 A)	9/6/2019	9/11/2019	A9I0145-10	Lead	ND	0.20	15	ppb
232-CH-5238-B-PP02-A	Hallway (40 A)	9/6/2019	9/11/2019	A9I0145-11	Lead	ND	0.20	15	ppb
232-CH-5702-A-PP02-A	Cafeteria	9/6/2019	9/11/2019	A9I0145-12	Lead	ND	0.20	15	ppb
232-CH-5702-B-PP02-A	Cafeteria	9/6/2019	9/11/2019	A9I0145-13	Lead	ND	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb