

**Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Arleta (232) - Pilot Week 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
232-CH-5220-A-PP03-A	Hallway (17)	9/13/2019	9/18/2019	A9I0463-23	Lead	ND	0.20	15	ppb
232-CH-5220-B-PP03-A	Hallway (17)	9/13/2019	9/18/2019	A9I0463-24	Lead	ND	0.20	15	ppb
232-CH-5220-C-PP03-A	Hallway (17)	9/13/2019	9/18/2019	A9I0463-25	Lead	ND	0.20	15	ppb
232-CH-5225-A-PP03-A	Hallway (7)	9/13/2019	9/18/2019	A9I0463-26	Lead	ND	0.20	15	ppb
232-CH-5225-B-PP03-A	Hallway (7)	9/13/2019	9/18/2019	A9I0463-27	Lead	ND	0.20	15	ppb
232-CH-5225-C-PP03-A	Hallway (7)	9/13/2019	9/18/2019	A9I0463-28	Lead	ND	0.20	15	ppb
232-CH-5234-A-PP03-A	Hallway (3)	9/13/2019	9/18/2019	A9I0463-29	Lead	ND	0.20	15	ppb
232-CH-5234-B-PP03-A	Hallway (3)	9/13/2019	9/18/2019	A9I0463-30	Lead	ND	0.20	15	ppb
232-CH-5234-C-PP03-A	Hallway (3)	9/13/2019	9/18/2019	A9I0463-31	Lead	ND	0.20	15	ppb
232-CH-5238-A-PP03-A	Hallway (40 A)	9/13/2019	9/18/2019	A9I0463-32	Lead	ND	0.20	15	ppb
232-CH-5238-B-PP03-A	Hallway (40 A)	9/13/2019	9/18/2019	A9I0463-33	Lead	ND	0.20	15	ppb
232-CH-5702-A-PP03-A	Cafeteria	9/13/2019	9/18/2019	A9I0463-34	Lead	ND	0.20	15	ppb
232-CH-5702-B-PP03-A	Cafeteria	9/13/2019	9/18/2019	A9I0463-35	Lead	ND	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb