

**Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Arleta (232) - Pilot Week 4 Results**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
232-CH-5220-A-PP04-A	Hallway (17)	9/20/2019	9/24/2019	A9I0648-01	Lead	ND	0.20	15	ppb
232-CH-5220-B-PP04-A	Hallway (17)	9/20/2019	9/24/2019	A9I0648-02	Lead	ND	0.20	15	ppb
232-CH-5220-C-PP04-A	Hallway (17)	9/20/2019	9/24/2019	A9I0648-03	Lead	ND	0.20	15	ppb
232-CH-5225-A-PP04-A	Hallway (7)	9/20/2019	9/24/2019	A9I0648-04	Lead	ND	0.20	15	ppb
232-CH-5225-B-PP04-A	Hallway (7)	9/20/2019	9/24/2019	A9I0648-05	Lead	ND	0.20	15	ppb
232-CH-5225-C-PP04-A	Hallway (7)	9/20/2019	9/24/2019	A9I0648-06	Lead	ND	0.20	15	ppb
232-CH-5234-A-PP04-A	Hallway (3)	9/20/2019	9/24/2019	A9I0648-07	Lead	ND	0.20	15	ppb
232-CH-5234-B-PP04-A	Hallway (3)	9/20/2019	9/24/2019	A9I0648-08	Lead	ND	0.20	15	ppb
232-CH-5234-C-PP04-A	Hallway (3)	9/20/2019	9/24/2019	A9I0648-09	Lead	ND	0.20	15	ppb
232-CH-5238-A-PP04-A	Hallway (40 A)	9/20/2019	9/24/2019	A9I0648-10	Lead	ND	0.20	15	ppb
232-CH-5238-B-PP04-A	Hallway (40 A)	9/20/2019	9/24/2019	A9I0648-11	Lead	ND	0.20	15	ppb
232-CH-5702-A-PP04-A	Cafeteria	9/20/2019	9/24/2019	A9I0648-12	Lead	ND	0.20	15	ppb
232-CH-5702-B-PP04-A	Cafeteria	9/20/2019	9/24/2019	A9I0648-13	Lead	ND	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb