

**Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Arleta (232) - Pilot Week 6 Results**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
232-CH-5220-A-PP06-A	Hallway (17)	10/4/2019	10/8/2019	A9I0909-01	Lead	ND	0.20	15	ppb
232-CH-5220-B-PP06-A	Hallway (17)	10/4/2019	10/8/2019	A9I0909-02	Lead	ND	0.20	15	ppb
232-CH-5220-C-PP06-A	Hallway (17)	10/4/2019	10/8/2019	A9I0909-03	Lead	ND	0.20	15	ppb
232-CH-5225-A-PP06-A	Hallway (7)	10/4/2019	10/8/2019	A9I0909-04	Lead	ND	0.20	15	ppb
232-CH-5225-B-PP06-A	Hallway (7)	10/4/2019	10/8/2019	A9I0909-05	Lead	ND	0.20	15	ppb
232-CH-5225-C-PP06-A	Hallway (7)	10/4/2019	10/8/2019	A9I0909-06	Lead	ND	0.20	15	ppb
232-CH-5234-A-PP06-A	Hallway (3)	10/4/2019	10/8/2019	A9I0909-07	Lead	ND	0.20	15	ppb
232-CH-5234-B-PP06-A	Hallway (3)	10/4/2019	10/8/2019	A9I0909-08	Lead	ND	0.20	15	ppb
232-CH-5234-C-PP06-A	Hallway (3)	10/4/2019	10/8/2019	A9I0909-09	Lead	ND	0.20	15	ppb
232-CH-5238-A-PP06-A	Hallway (40 A)	10/4/2019	10/8/2019	A9I0909-10	Lead	ND	0.20	15	ppb
232-CH-5238-B-PP06-A	Hallway (40 A)	10/4/2019	10/9/2019	A9I0909-11	Lead	0.38	0.20	15	ppb
232-CH-5702-A-PP06-A	Cafeteria	10/4/2019	10/8/2019	A9I0909-12	Lead	ND	0.20	15	ppb
232-CH-5702-B-PP06-A	Cafeteria	10/4/2019	10/8/2019	A9I0909-13	Lead	ND	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb