

**Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Arleta Elementary School (232) - Pilot Test 16 Results**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
232-CH-5220-A-PP16-A	Hallway (17)	2/7/2020	2/11/2020	A0B0204-01	Lead	ND	0.20	15	ppb
232-CH-5225-A-PP16-A	Hallway (7)	2/7/2020	2/11/2020	A0B0204-02	Lead	ND	0.20	15	ppb
232-CH-5234-A-PP16-A	Hallway (3)	2/7/2020	2/11/2020	A0B0204-03	Lead	4.14	0.20	15	ppb
232-CH-5238-A-PP16-A	Hallway (40 A)	2/7/2020	2/11/2020	A0B0204-04	Lead	ND	0.20	15	ppb
232-CH-5702-A-PP16-A	Cafeteria	2/7/2020	2/11/2020	A0B0204-05	Lead	0.319	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb