

**Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Arleta Elementary School (232) - Pilot Test 18 Results**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
232-CH-5220-A-PP18-A	Hallway (17)	3/6/2020	3/11/2020	A0C0231-01	Lead	ND	0.20	15	ppb
232-CH-5225-A-PP18-A	Hallway (7)	3/6/2020	3/11/2020	A0C0231-02	Lead	ND	0.20	15	ppb
232-CH-5234-A-PP18-A	Hallway (3)	3/6/2020	3/11/2020	A0C0231-03	Lead	ND	0.20	15	ppb
232-CH-5238-A-PP18-A	Hallway (40 A)	3/6/2020	3/11/2020	A0C0231-04	Lead	ND	0.20	15	ppb
232-CH-5702-A-PP18-A	Cafeteria	3/6/2020	3/11/2020	A0C0231-05	Lead	0.279	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb