Portland Public Schools
Pilot Study Lead Sampling Results
Initial Flush Sample Data
Duniway (244) - Test PP01 - Week 1

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
244-CH-1096-A-PP01-A	Hallway (1)	8/19/2019	8/20/2019	A9H0599-10	Lead	0.421	0.20	15	ppb
244-CH-1096-B-PP01-A	Hallway (1)	8/19/2019	8/20/2019	A9H0599-11	Lead	ND	0.20	15	ppb
244-CH-1096-C-PP01-A	Hallway (1)	8/19/2019	8/20/2019	A9H0599-12	Lead	ND	0.20	15	ppb
244-CH-1088-A-PP01-A	Hallway (12)	8/19/2019	8/20/2019	A9H0599-13	Lead	ND	0.20	15	ppb
244-CH-1088-B-PP01-A	Hallway (12)	8/19/2019	8/20/2019	A9H0599-14	Lead	ND	0.20	15	ppb
244-CH-1088-C-PP01-A	Hallway (12)	8/19/2019	8/20/2019	A9H0599-15	Lead	ND	0.20	15	ppb
244-CH-1094-A-PP01-A	Cafeteria	8/19/2019	8/21/2019	A9H0599-16	Lead	ND	0.20	15	ppb
244-CH-1094-B-PP01-A	Cafeteria	8/19/2019	8/21/2019	A9H0599-17	Lead	3.19	0.20	15	ppb
244-CH-1068-A-PP01-A	Hallway (16)	8/19/2019	8/21/2019	A9H0599-18	Lead	2.8	0.20	15	ppb
244-CH-1068-B-PP01-A	Hallway (16)	8/19/2019	8/21/2019	A9H0599-19	Lead	1	0.20	15	ppb
244-CH-1068-C-PP01-A	Hallway (16)	8/19/2019	8/21/2019	A9H0599-20	Lead	0.449	0.20	15	ppb
244-CH-1098-A-PP01-A	Hallway (25)	8/19/2019	8/20/2019	A9H0599-21	Lead	0.226	0.20	15	ppb
244-CH-1098-B-PP01-A	Hallway (25)	8/19/2019	8/20/2019	A9H0599-22	Lead	ND	0.20	15	ppb
244-CH-1098-C-PP01-A	Hallway (25)	8/19/2019	8/21/2019	A9H0599-23	Lead	0.612	0.20	15	ppb

*OHA Action Level = 15ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek