

Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Duniway (244) - Week 3 Pilot Results

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
244-CH-1068-A-PP03-A	Hallway (16)	9/13/2019	9/18/2019	A9I0463-36	Lead	0.342	0.20	15	ppb
244-CH-1068-C-PP03-A	Hallway (16)	9/13/2019	9/18/2019	A9I0463-37	Lead	0.259	0.20	15	ppb
244-CH-1068-B-PP03-A	Hallway (16)	9/13/2019	9/18/2019	A9I0463-38	Lead	ND	0.20	15	ppb
244-CH-1088-A-PP03-A	Hallway (12)	9/13/2019	9/18/2019	A9I0463-39	Lead	ND	0.20	15	ppb
244-CH-1088-B-PP03-A	Hallway (12)	9/13/2019	9/18/2019	A9I0463-40	Lead	ND	0.20	15	ppb
244-CH-1088-C-PP03-A	Hallway (12)	9/13/2019	9/18/2019	A9I0463-41	Lead	ND	0.20	15	ppb
244-CH-1094-A-PP03-A	Cafeteria	9/13/2019	9/18/2019	A9I0463-42	Lead	0.7	0.20	15	ppb
244-CH-1094-B-PP03-A	Cafeteria	9/13/2019	9/18/2019	A9I0463-43	Lead	ND	0.20	15	ppb
244-CH-1096-A-PP03-A	Hallway (1)	9/13/2019	9/18/2019	A9I0463-44	Lead	ND	0.20	15	ppb
244-CH-1096-B-PP03-A	Hallway (1)	9/13/2019	9/18/2019	A9I0463-45	Lead	ND	0.20	15	ppb
244-CH-1096-C-PP03-A	Hallway (1)	9/13/2019	9/18/2019	A9I0463-46	Lead	ND	0.20	15	ppb
244-CH-1098-A-PP03-A	Hallway (25)	9/13/2019	9/18/2019	A9I0463-47	Lead	0.38	0.20	15	ppb
244-CH-1098-B-PP03-A	Hallway (25)	9/13/2019	9/18/2019	A9I0463-48	Lead	ND	0.20	15	ppb
244-CH-1098-C-PP03-A	Hallway (25)	9/13/2019	9/18/2019	A9I0463-49	Lead	ND	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb