

**Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Duniway (244) - Week 5 Pilot Results**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
244-CH-1068-A-PP05-A	Hallway (16)	9/27/2019	9/30/2019	A9I0909-14	Lead	1.39	0.20	15	ppb
244-CH-1068-B-PP05-A	Hallway (16)	9/27/2019	9/30/2019	A9I0909-15	Lead	ND	0.20	15	ppb
244-CH-1068-C-PP05-A	Hallway (16)	9/27/2019	9/30/2019	A9I0909-16	Lead	2.59	0.20	15	ppb
244-CH-1088-A-PP05-A	Hallway (12)	9/27/2019	9/30/2019	A9I0909-17	Lead	ND	0.20	15	ppb
244-CH-1088-B-PP05-A	Hallway (12)	9/27/2019	9/30/2019	A9I0909-18	Lead	ND	0.20	15	ppb
244-CH-1088-C-PP05-A	Hallway (12)	9/27/2019	9/30/2019	A9I0909-19	Lead	ND	0.20	15	ppb
244-CH-1094-A-PP05-A	Cafeteria	9/27/2019	9/30/2019	A9I0909-20	Lead	1.42	0.20	15	ppb
244-CH-1094-B-PP05-A	Cafeteria	9/27/2019	9/30/2019	A9I0909-21	Lead	ND	0.20	15	ppb
244-CH-1096-A-PP05-A	Hallway (1)	9/27/2019	9/30/2019	A9I0909-22	Lead	ND	0.20	15	ppb
244-CH-1096-B-PP05-A	Hallway (1)	9/27/2019	9/30/2019	A9I0909-23	Lead	ND	0.20	15	ppb
244-CH-1096-C-PP05-A	Hallway (1)	9/27/2019	9/30/2019	A9I0909-24	Lead	0.302	0.20	15	ppb
244-CH-1098-A-PP05-A	Hallway (25)	9/27/2019	9/30/2019	A9I0909-25	Lead	0.654	0.20	15	ppb
244-CH-1098-B-PP05-A	Hallway (25)	9/27/2019	9/30/2019	A9I0909-26	Lead	ND	0.20	15	ppb
244-CH-1098-C-PP05-A	Hallway (25)	9/27/2019	9/30/2019	A9I0909-27	Lead	0.277	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb