

**Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Duniway (244) - Week 6 Pilot Results**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
244-CH-1068-A-PP06-A	Hallway (16)	10/4/2019	10/9/2019	A9I0909-14	Lead	1.75	0.20	15	ppb
244-CH-1068-B-PP06-A	Hallway (16)	10/5/2019	10/9/2019	A9I0909-15	Lead	0.402	0.20	15	ppb
244-CH-1068-C-PP06-A	Hallway (16)	10/6/2019	10/9/2019	A9I0909-16	Lead	4.55	0.20	15	ppb
244-CH-1088-A-PP06-A	Hallway (12)	10/7/2019	10/7/2019	A9I0909-17	Lead	ND	0.20	15	ppb
244-CH-1088-B-PP06-A	Hallway (12)	10/8/2019	10/7/2019	A9I0909-18	Lead	ND	0.20	15	ppb
244-CH-1088-C-PP06-A	Hallway (12)	10/9/2019	10/7/2019	A9I0909-19	Lead	ND	0.20	15	ppb
244-CH-1094-A-PP06-A	Cafeteria	10/10/2019	10/8/2019	A9I0909-20	Lead	1.4	0.20	15	ppb
244-CH-1094-B-PP06-A	Cafeteria	10/11/2019	10/8/2019	A9I0909-21	Lead	0.267	0.20	15	ppb
244-CH-1096-A-PP06-A	Hallway (1)	10/12/2019	10/8/2019	A9I0909-22	Lead	ND	0.20	15	ppb
244-CH-1096-B-PP06-A	Hallway (1)	10/13/2019	10/8/2019	A9I0909-23	Lead	ND	0.20	15	ppb
244-CH-1096-C-PP06-A	Hallway (1)	10/14/2019	10/8/2019	A9I0909-24	Lead	0.319	0.20	15	ppb
244-CH-1098-A-PP06-A	Hallway (25)	10/15/2019	10/8/2019	A9I0909-25	Lead	2.56	0.20	15	ppb
244-CH-1098-B-PP06-A	Hallway (25)	10/16/2019	10/8/2019	A9I0909-26	Lead	ND	0.20	15	ppb
244-CH-1098-C-PP06-A	Hallway (25)	10/17/2019	10/8/2019	A9I0909-27	Lead	0.403	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb