

**Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Duniway (244) - Week 7 Pilot Results**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
244-CH-1068-A-PP07-A	Hallway (16)	10/11/2019	10/16/2019	A9I0909-14	Lead	2.21	0.20	15	ppb
244-CH-1088-A-PP07-A	Hallway (12)	10/11/2019	10/16/2019	A9I0909-17	Lead	ND	0.20	15	ppb
244-CH-1094-A-PP07-A	Cafeteria	10/11/2019	10/16/2019	A9I0909-20	Lead	3.01	0.20	15	ppb
244-CH-1096-A-PP07-A	Hallway (1)	10/11/2019	10/16/2019	A9I0909-22	Lead	ND	0.20	15	ppb
244-CH-1098-A-PP07-A	Hallway (25)	10/11/2019	10/16/2019	A9I0909-25	Lead	1.52	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb