

**Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Duniway (244) - Week 9 Pilot Results**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
244-CH-1068-A-PP09-A	Hallway (16)	10/25/2019	10/28/2019	A9J0934-06	Lead	4.89	0.20	15	ppb
244-CH-1088-A-PP09-A	Hallway (12)	10/25/2019	10/28/2019	A9J0934-07	Lead	ND	0.20	15	ppb
244-CH-1094-A-PP09-A	Cafeteria	10/25/2019	10/28/2019	A9J0934-08	Lead	4.55	0.20	15	ppb
244-CH-1096-A-PP09-A	Hallway (1)	10/25/2019	10/28/2019	A9J0934-09	Lead	ND	0.20	15	ppb
244-CH-1098-A-PP09-A	Hallway (25)	10/25/2019	10/28/2019	A9J0934-10	Lead	0.846	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb